

MEGHALAYA POWER LIMITED (1*43 MW)
Lumshnong, Meghalaya

STACK EMISSION MONITORING RESULTS (JUNE – 2013)
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	28.15

AMBIENT AIR QUALITY MONITORING RESULTS (JUNE – 2013)
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		43.44	26.58	9.50	10.91
Station #2 (Near Steel Yard)		52.84	32.75	8.45	11.88
Station #3 (Near ADM Office)		49.53	29.16	7.11	9.39
Station #4 (Near CHP Screen)		57.89	35.57	8.58	13.2