

MEGHALAYA POWER LIMITED
(1x43 MW)

April - 2014

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	30.04

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		57.48	36.99	7.38	10.43
Station #2 (Near Steel Yard)		56.08	35.60	8.18	9.61
Station #3 (Near ADM Office)		52.18	30.91	5.68	9.17
Station #4 (Near CHP Screen)		62.07	39.32	8.55	12.39