

MEGHALAYA POWER LIMITED
(1x43 MW)

January - 2014

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	32.52

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		55.98	34.09	7.3	10.39
Station #2 (Near Steel Yard)		57.25	37.18	8.24	10.89
Station #3 (Near ADM Office)		51.04	31.96	6.49	9.77
Station #4 (Near CHP Screen)		60.03	38.89	7.84	11.87