

MEGHALAYA POWER LIMITED
(1x43 MW)

May - 2014

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	33.85

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		60.68	37.54	7.50	10.82
Station #2 (Near Steel Yard)		70.78	40.67	8.37	10.19
Station #3 (Near ADM Office)		60.29	34.97	6.58	9.91
Station #4 (Near CHP Screen)		70.62	40.92	7.73	12.49