

MEGHALAYA POWER LIMITED
(1x43 MW)

December - 2014

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	24.14

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		60.66	39.19	6.96	9.87
Station #2 (Near Steel Yard)		69.98	47.59	8.36	10.32
Station #3 (Near ADM Office)		66.47	46.32	7.36	10.28
Station #4 (Near CHP Screen)		72.10	49.60	8.46	11.37