

MEGHALAYA POWER LIMITED
(1x43 MW)

January - 2015

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	28.87

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		65.55	44.19	7.45	10.35
Station #2 (Near Steel Yard)		69.39	47.62	8.48	10.68
Station #3 (Near ADM Office)		64.69	43.44	7.41	10.58
Station #4 (Near CHP Screen)		71.84	49.37	8.57	11.61