

MEGHALAYA POWER LIMITED
(1x43 MW)

July - 2016

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm³)
1	Cooler ESP	23.14

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m³)		Gaseous Emission (µg/m³)	
		PM₁₀	PM_{2.5}	SO₂	NO₂
Station #1 (Behind MPL DM Plant)		52.78	32.24	6.35	9.30
Station #2 (Near Steel Yard)		51.40	30.34	5.92	9.45
Station #3 (Near ADM Office)		45.90	26.28	5.12	9.29
Station #4 (Near CHP Screen)		51.01	29.9	5.45	9.76