

MEGHALAYA POWER LIMITED
(1x43 MW)

June - 2016

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	24.45

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		56.67	36.33	7.49	10.54
Station #2 (Near Steel Yard)		55.68	34.85	7.02	10.21
Station #3 (Near ADM Office)		50.41	29.54	6.44	9.55
Station #4 (Near CHP Screen)		56.84	36.38	7.10	10.49