

MEGHALAYA POWER LIMITED
(1x43 MW)

November - 2014

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	28.55

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		59.89	38.42	6.88	9.80
Station #2 (Near Steel Yard)		70.58	47.05	8.41	10.70
Station #3 (Near ADM Office)		64.60	41.98	7.12	10.04
Station #4 (Near CHP Screen)		72.18	47.52	8.23	10.72