

**MEGHALAYA POWER LIMITED**  
**(1x43 MW)**

---

October - 2014

**STACK EMISSION MONITORING RESULTS**  
**(Average Values)**

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm <sup>3</sup> )
1	Cooler ESP	28.70

**AMBIENT AIR QUALITY MONITORING RESULTS**  
**(Average Values)**

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m <sup>3</sup> )		Gaseous Emission (µg/m <sup>3</sup> )	
		PM <sub>10</sub>	PM <sub>2.5</sub>	SO <sub>2</sub>	NO <sub>2</sub>
Station #1 (Behind MPL DM Plant)		56.51	34.85	6.53	9.68
Station #2 (Near Steel Yard)		61.02	40.63	8.22	10.10
Station #3 (Near ADM Office)		57.59	34.51	6.35	9.90
Station #4 (Near CHP Screen)		59.45	37.48	6.98	10.72