

MEGHALAYA POWER LIMITED
(1x43 MW)

August - 2015

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	22.87

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		50.77	29.82	5.74	9.36
Station #2 (Near Steel Yard)		52.84	31.3	5.72	9.28
Station #3 (Near ADM Office)		48.17	27.77	5.19	9.28
Station #4 (Near CHP Screen)		52.91	32.27	5.7	9.12