

MEGHALAYA POWER LIMITED
(1x43 MW)

December - 2015

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	23.23

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		56.26	36.20	6.84	9.90
Station #2 (Near Steel Yard)		57.86	37.05	7.48	9.64
Station #3 (Near ADM Office)		51.80	31.93	6.71	9.28
Station #4 (Near CHP Screen)		58.31	38.30	7.26	10.06