

MEGHALAYA POWER LIMITED
(1x43 MW)

January - 2016

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	23.22

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		57.39	36.81	7.19	10.12
Station #2 (Near Steel Yard)		65.19	44.07	8.20	10.65
Station #3 (Near ADM Office)		56.55	36.17	6.05	10.15
Station #4 (Near CHP Screen)		67.04	46.48	8.74	10.30