

MEGHALAYA POWER LIMITED
(1x43 MW)

June - 2015

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	23.15

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		53.19	32.27	6.70	10.18
Station #2 (Near Steel Yard)		55.20	33.97	7.27	10.22
Station #3 (Near ADM Office)		50.17	29.31	5.73	9.73
Station #4 (Near CHP Screen)		55.69	34.17	6.89	9.65