

MEGHALAYA POWER LIMITED
(1x43 MW)

May - 2015

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	25.01

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		54.61	33.57	6.93	10.29
Station #2 (Near Steel Yard)		54.73	33.34	7.03	10.43
Station #3 (Near ADM Office)		51.32	29.94	5.64	9.22
Station #4 (Near CHP Screen)		56.43	34.84	7.17	10.18