

MEGHALAYA POWER LIMITED
(1x43 MW)

October - 2015

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	23.87

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		52.52	32.00	6.14	9.53
Station #2 (Near Steel Yard)		57.14	35.51	7.70	9.22
Station #3 (Near ADM Office)		50.34	28.57	5.65	9.24
Station #4 (Near CHP Screen)		57.29	37.78	7.86	9.70