

MEGHALAYA POWER LIMITED
(1x43 MW)

September - 2015

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	Cooler ESP	20.42

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		51.07	30.07	6.06	9.36
Station #2 (Near Steel Yard)		56.43	33.98	6.26	9.51
Station #3 (Near ADM Office)		50.42	29.55	5.25	9.64
Station #4 (Near CHP Screen)		56.96	35.84	6.50	9.70