



EASTERN ENVO PROTECT

(RESEARCH AND DEVELOPMENT DIVISION)

AGRO-VET FARM CARE AND ENVIRONMENTAL PROTECTION LABORATORY

Progoti Commercial Complex (Opp. Down Town Hospital)

G.S. Road Guwahati-781022 Assam

TEST CERTIFICATE

WATER ANALYSIS REPORT

DATE	17/08/2013
REF. NO	ENVOLAB/GHY/105/13-14

Sample Location:
M/s Cement Manufacturing
Company Ltd.
Gopinath Bordoloi Road,
Chamtha pathar,
Sonapur-782402, Kamrup,
Assam.

Date of Collection	11.08.2013
Sample Collected By	M/s. EASTERN ENVO PROTECT, ENVO LAB, R & D DIVISION,

SL.NO	PARAMETERS	LIMITS (as per IS: 2296)	RESULTS
1	pH	8.5	7.7
2	Alkainity	≤600 mg/L	
	a) Phenolphthalein		26
	b) Total		380
3	Conductivity	-	0.032
4	Total Dissolved Solid(TDS)	500 mg/L	321
5	Total Suspended Solids(TSS)	100 mg/L	60
6	Turbidity	5 NTU	0.1
7	Chloride	250 mg/L	43.05
8	Oil and Grease	0.1 mg/L	0.04
9	Hardness	300 mg/L	190

Method of Analysis Followed: I.S. 3025

Opinion : All the parameters are under permissible limit.

EASTERN ENVO PROTECT, ENVO LAB, R & D DIVISION

(Quality Control Manager)

End of Report