

MEGHALAYA POWER LIMITED
(1×43 MW)

August – 2017

STACK EMISSION MONITORING RESULTS
(Average Values)

S. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	ESP	22.82

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		45.33	26.35	6.58	9.32
Station #2 (Near Steel Yard)		47.52	29.05	6.61	9.10
Station #3 (Near ADM Office)		41.16	25.70	6.19	9.03
Station #4 (Near CHP Screen)		46.33	27.63	7.07	9.29