

MEGHALAYA POWER LIMITED
(1x43 MW)

December- 2016

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm³)
1	ESP	21.92

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m³)		Gaseous Emission (µg/m³)	
		PM₁₀	PM_{2.5}	SO₂	NO₂
Station #1 (Behind MPL DM Plant)		71.25	50.09	12.86	14.18
Station #2 (Near Steel Yard)		71.01	49.26	13.22	17.01
Station #3 (Near ADM Office)		67.12	46.46	8.62	10.00
Station #4 (Near CHP Screen)		72.85	51.87	14.65	17.55