

MEGHALAYA POWER LIMITED
(1x43 MW)

February- 2017

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	ESP	23.50

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		71.34	49.00	8.37	12.43
Station #2 (Near Steel Yard)		73.96	51.85	10.26	16.02
Station #3 (Near ADM Office)		64.46	43.50	6.02	9.84
Station #4 (Near CHP Screen)		70.90	49.27	11.61	15.32