

MEGHALAYA POWER LIMITED
(1x43 MW)

January- 2017

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	ESP	21.27

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		75.12	53.45	12.55	14.78
Station #2 (Near Steel Yard)		73.20	52.20	12.25	15.64
Station #3 (Near ADM Office)		64.71	43.20	8.62	10.54
Station #4 (Near CHP Screen)		75.65	53.50	12.40	17.25