

**MEGHALAYA POWER LIMITED**  
**(1x43 MW)**

---

July- 2018

**STACK EMISSION MONITORING RESULTS**  
**(Average Values)**

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm <sup>3</sup> )
1	ESP	18.9

**AMBIENT AIR QUALITY MONITORING RESULTS**  
**(Average Values)**

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m <sup>3</sup> )		Gaseous Emission (µg/m <sup>3</sup> )	
		PM <sub>10</sub>	PM <sub>2.5</sub>	SO <sub>2</sub>	NO <sub>2</sub>
Station #1 (Behind MPL DM Plant)		49.6	31.3	9.2	39.7
Station #2 (Near Steel Yard)		58.2	34.9	7.7	12.9
Station #3 (Near ADM Office)		69.4	41.6	9.1	13.6
Station #4 (Near CHP Screen)		76.1	45.6	10.4	16.0

**FUGITIVE EMISSION MONITORING RESULTS**  
**(Average Values)**

Location	Fugitive Emission Results (in µg/m <sup>3</sup> )	Limit (in µg/m <sup>3</sup> )
Coal Storage Section	1354	2000