

MEGHALAYA POWER LIMITED
(1x43 MW)

June - 2017

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	ESP	25.64

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		69.73	40.11	9.96	14.14
Station #2 (Near Steel Yard)		69.03	38.10	9.54	14.33
Station #3 (Near ADM Office)		64.91	34.49	8.22	11.74
Station #4 (Near CHP Screen)		70.09	39.44	9.11	13.25