

MEGHALAYA POWER LIMITED
(1x43 MW)

March - 2017

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	ESP	18.64

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		64.56	35.83	6.86	10.31
Station #2 (Near Steel Yard)		65.70	35.20	6.84	10.17
Station #3 (Near ADM Office)		59.83	29.31	6.13	9.63
Station #4 (Near CHP Screen)		47.30	29.59	5.71	8.81