

MEGHALAYA POWER LIMITED
(1x43 MW)

May - 2017

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	ESP	24.63

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		70.19	40.19	9.76	14.07
Station #2 (Near Steel Yard)		70.28	37.40	8.45	13.19
Station #3 (Near ADM Office)		67.57	35.25	8.78	12.44
Station #4 (Near CHP Screen)		71.90	38.86	9.28	14.80