

MEGHALAYA POWER LIMITED
(1x43 MW)

October - 2016

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	ESP	Plant shut down

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		57.83	37.27	7.68	10.53
Station #2 (Near Steel Yard)		58.17	37.98	6.97	9.87
Station #3 (Near ADM Office)		54.46	33.73	6.40	9.37
Station #4 (Near CHP Screen)		59.22	38.25	7.19	10.36