

MEGHALAYA POWER LIMITED
(1x43 MW)

December - 2017

STACK EMISSION MONITORING RESULTS
(Average Values)

Sl. No.	Stack Attached To	Particulate Matter (mg/Nm ³)
1	ESP	26.72

AMBIENT AIR QUALITY MONITORING RESULTS
(Average Values)

Stations ↓	Parameters →	Respirable Suspended particulate Matter (µg/m ³)		Gaseous Emission (µg/m ³)	
		PM ₁₀	PM _{2.5}	SO ₂	NO ₂
Station #1 (Behind MPL DM Plant)		48.84	32.55	9.79	11.86
Station #2 (Near Steel Yard)		53.87	33.89	11.03	12.27
Station #3 (Near ADM Office)		44.35	29.00	9.13	10.61
Station #4 (Near CHP Screen)		49.83	32.79	11.00	12.30