

MEGHALAYA POWER LIMITED (8MW) Lumshnong, Meghalaya		Reference No.		MPL/Env/F – 01
		Issue No.		1
		Date of Issue:		24.08.2013
AMBIENT AIR QUALITY MONITORING REPORT		Revision No.		5
		Date of Rev.		01.12.2020
Reference No.: MPL (8 MW)/ENV/AAQM/MONTHLY/2022-23/36		Month: June'22		
Location of Sampling: Near ADM Office (South)		GPS Coordinate: 25°10'34"N 92°23'46"E 907 m		
Sampling Duration:	24 Hrs.	24 Hrs.	24 Hrs.	24 Hrs.
Date of Sampling	PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	SO ₂ (µg/m ³)	NO ₂ (µg/m ³)
No Monitoring Due To Heavy Rainfall				
NAAQS permissible limits for Rural, Industrial, Residential Area	100 (µg/m ³)	60 (µg/m ³)	80 (µg/m ³)	80 (µg/m ³)

Remarks: All the analyzed parameters are well within the permissible limits of NAAQ Standards , Notification dated 18th November 2009.


Analysed by



Checked by


Verified By

MEGHALAYA POWER LIMITED (8MW) Lumshnong, Meghalaya		Reference No.		MPL/Env/F – 01
		Issue No.		1
		Date of Issue:		24.08.2013
AMBIENT AIR QUALITY MONITORING REPORT		Revision No.		5
		Date of Rev.		01.12.2020
Reference No.: MPL (8 MW)/ENV/AAQM/MONTHLY/2022-23/37		Month: June'22		
Location of Sampling: Near STP		GPS Coordinate: 25°10'49"N 92°23'58"E 947 m		
Sampling Duration:	24 Hrs.	24 Hrs.	24 Hrs.	24 Hrs.
Date of Sampling	PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	SO ₂ (µg/m ³)	NO ₂ (µg/m ³)
No Monitoring Due To Heavy Rainfall				
NAAQS permissible limits for Rural, Industrial, Residential Area	100 (µg/m ³)	60 (µg/m ³)	80 (µg/m ³)	80 (µg/m ³)

Remarks: All the analyzed parameters are well within the permissible limits of NAAQ Standards , Notification dated 18th November 2009.


Analysed by


Checked by


Verified By




MEGHALAYA POWER LIMITED (8MW) Lumshnong, Meghalaya		Reference No.		MPL/Env/F – 01
		Issue No.		1
		Date of Issue:		24.08.2013
AMBIENT AIR QUALITY MONITORING REPORT		Revision No.		5
		Date of Rev.		01.12.2020
Reference No.: MPL (8 MW)/ENV/AAQM/MONTHLY/2022-23/38		Month: June'22		
Location of Sampling: Near Piezometer		GPS Coordinate: 25°10'35"N 92°23'53"E 348 m		
Sampling Duration:	24 Hrs.	24 Hrs.	24 Hrs.	24 Hrs.
Date of Sampling	PM ₁₀ (µg/m ³)	PM _{2.5} (µg/m ³)	SO ₂ (µg/m ³)	NO ₂ (µg/m ³)
No Monitoring Due To Heavy Rainfall				
NAAQS permissible limits for Rural, Industrial, Residential Area	100 (µg/m ³)	60 (µg/m ³)	80 (µg/m ³)	80 (µg/m ³)

Remarks: All the analyzed parameters are well within the permissible limits of NAAQ Standards , Notification dated 18th November 2009.


Analysed by


Checked by


Verified By

MEGHALAYA POWER LIMITED Lumshnong, Meghalaya		Reference No.	MPL/Env/F-02
		Issue No.	1
		Date of Issue:	01.05.2019
STACK EMISSION MONITORING ANALYSIS REPORT		Revision No.	5
		Date of Rev.	01.06.2021
Report No: MPL/Env/Stack/Monthly/2022-23/07		Month: June'22	
<u>Analysis Result</u>			
A.	General Information About Stack		
1	Stack Identification No	8 MW	
2	Stack Connected to	Boiler	
3	Material of Construction (Stack/Duct)	Mild Steel	
4	Shape of duct	Circular	
5	Whether duct is provided with permanent platform & ladder	Yes	
B.	Physical characteristic of stack		
1	Stack Height from ground level (meter)	45	
2	Duct diameter at sampling point (meter)	2.08	
3	Sampling height point from ground level (meter)	11	
4	Cross sectional area of Duct/Stack (m ²)	3.4	
C.	Pollution Control Device		
1	Details of pollution control device attached to stack	ESP	
D.	Result of Sampling & Analysis of Gaseous Emission		
1	Date of Sampling	-	
2	Ambient Temp (°C)	-	
3	Stack Gas Temp (°C)	-	
4	Exit Velocity of Gas (m/sec.)	-	
5	Flow Rate (Nm ³ / sec.)	-	
6	Quantity of Emission (Nm ³ / Hr)	-	
7	Concentration of PM (mg/Nm ³)	-	
8	Concentration of SO ₂ (mg/Nm ³)	-	
9	Concentration of NO _x (mg/Nm ³)	-	
10	Oxygen (O ₂) (%)	-	
E.	Remarks: Monitoring of 8MW Boiler stack has not carried out due to shut down.		
Standard			
PM - 50 mg/Nm ³		SO ₂ - 600 mg/Nm ³	NO _x - 300 mg/Nm ³
Particulate Matter (PM), Sulphur di-oxide (SO ₂), Oxide of Nitrogen (Nox), Electro Static Precipitator (ESP)			
<div style="display: flex; justify-content: space-around; align-items: flex-end;"> <div style="text-align: center;">  Analysis by </div> <div style="text-align: center;">  Checked by </div> <div style="text-align: center;">  Authorized Signatory </div> </div>			

MEGHALAYA POWER LIMITED Lumshnong, Meghalaya		Document No.	MPL/EHS/Env/F-04
		Date of Issued	01-05-2019
		Revision No.	2
FUGITIVE EMISSION MONITORING REPORT		Revision Date	01-01-2021
Ref: MPL/ENV/FUGITIVE/MONTHLY/2022-23/015 Month - June 2022			
Location	Fugitive Emission Results	Limit	
	(in $\mu\text{g}/\text{m}^3$)	(in $\mu\text{g}/\text{m}^3$)	
Coal Storage Section	Due to Heavy Rain fall	2000	



Analyzed By




Checked By



Verified By

MEGHALAYA POWER LIMITED (8 MW) Lumshnong, Meghalaya					Document No.		MPL/EHS/Env/F-03		
					Date of Issued		01-05-2019		
					Revision No.		04		
NOISE LEVEL MONITORING REPORT					Revision Date		01-01-2021		
Ref: MPL(8MW)/ENV/NOISE/MONTHLY/2021-22/007							Date: 02.06.2022		
Month - June 2022									
S. No.	Location	Measured Values dB(A) Day time (6:00am to 10:00pm)			Norms In dB(A)	Measured Values dB(A) Night time (10:00pm to 6:00am)			Norms in dB(A)
		Min.	Max.	Avg.		Min.	Max.	Avg.	
A	Plant								
1	Turbine House Ground Floor	63.8	68.3	66.1	75	60.0	66.7	63.4	70
2	Turbine House 9 Mt.	60.7	70.5	65.6		56.9	65.9	61.4	
3	RO – MCC	64.6	71.0	67.8		60.2	66.0	63.1	
4	Boiler Ground Floor	65.1	70.2	67.7		59.0	64.9	62.0	
5	CHP – MCC	64.6	71.1	67.9		53.2	57.0	55.1	
6	Office Area	58.9	68.1	63.5		50.7	64.2	57.5	


Analyzed by


Checked By


Verified By:

MEGHALAYA POWER LIMITED Lumshnong, Meghalaya	Reference No.	SCML/EHS/F-04
	Issue No.	1
	Date of Issue:	24.08.2013
	Revision No.	3
WATER TESTING REPORT	Date of Rev.	01.06.2019

Report No. - 03			Date of sample collection: - 14.06.2022 Date of Analysis: 14.06.2022 to 17.06.2022	
Sr.No.	Parameter	Unit	STP Inlet	Standard Norms For Discharge of Environment Pollution (Notification Date: - 19th May 1993) & Consent To Operate vide letter no. MPCB/TB-900 (Pt-II)/2014- 2015/34 - dated Shillong, the 3rd Sep,2014
1	pH	-	7.50	-
2	Colour	Hazen	Colourless	-
3	Odour	-	Odourless	-
4	Chloride	mg/L	61.2	-
5	Total Hardness as CaCO ₃	mg/L	145.0	-
6	Suspended Solids	mg/L	80.0	-
7	Total Dissolve Solids	mg/L	240	-
8	Chemical Oxygen Demand	mg/L	175	-
9	Biochemical Oxygen Demand (For 3 days at 27 °C)	mg/L	98.0	-
10	Oil & Grease	mg/L	8.0	-
11	Temperature	° C	24.0	-
12	Conductivity	μS/cm	430.0	-



Analysis By



Checked BY



Verified By

MEGHALAYA POWER LIMITED Lumshnong, Meghalaya	Reference No.	SCML/EHS/F-04
	Issue No.	1
	Date of Issue:	24.08.2013
	Revision No.	3
WATER TESTING REPORT	Date of Rev.	01.06.2019

Report No. - 03			Date of sample collection: - 14.06.2022 Date of Analysis: 14.06.2022 to 17.06.2022	
Sr.No.	Parameter	Unit	STP Outlet	Standard Norms For Discharge of Environment Pollution (Notification Date: - 19th May 1993) & Consent To Operate vide letter no. MPCB/TB-900 (Pt-II)/2014- 2015/34 - dated Shillong, the 3rd Sep,2014
1	pH	-	7.80	5.5 to 9.0
2	Colour	Hazen	Colourless	-
3	Odour	-	Odourless	-
4	Chloride	mg/L	47.5	-
5	Total Hardness as CaCO ₃	mg/L	130.7	-
6	Suspended Solids	mg/L	7.9	100
7	Total Dissolve Solids	mg/L	310	-
8	Chemical Oxygen Demand	mg/L	25.0	250
9	Biochemical Oxygen Demand (For 3 days at 27 °C)	mg/L	5.2	30
10	Oil & Grease	mg/L	< 3.0	10
11	Temperature	° C	24.5	Shall not exceed 5.0°C above the receiving water temperature
12	Conductivity	µS/cm	490	-



Analysis By



Checked BY



Verified By

MEGHALAYA POWER LIMITED Lumshnong, Meghalaya	Reference No.	SCL/EHS/F-04
	Issue No.	1
	Date of Issue:	24.08.2013
	Revision No.	3
	Date of Rev.	01.06.2019
WATER TESTING REPORT		

Report No. - 14	Date of sample collection: - 13.06.2022 Date of Analysis: 13.06.2022 to 16.06.2022
-----------------	---

Sr.No.	Parameter	Unit	ETP Outlet	Standard Norms For Discharge of Environment Pollution (Notification Date:- 19th May 1993) & Consent To Operate vide letter no. MPCB/TB-900 (Pt-II)/2014-2015/34 – dated Shillong, the 3rd SEP, 2014.
1	pH	-	7.6	5.5 to 9.0
2	Suspended Solids	mg/L	14.9	100
3	Total Dissolve Solids	mg/L	244	-
4	Chemical Oxygen Demand	mg/L	29.2	250
5	Biochemical Oxygen Demand (For 3 days at 27 °C)	mg/L	5.8	30
6	Oil & Grease	mg/L	<3	10



Analysis By



Checked By



Verified By

MEGHALAYA POWER LIMITED Lumshnong, Meghalaya	Reference No.	SCL/EHS/F-04
	Issue No.	1
WATER TESTING REPORT	Date of Issue:	24.08.2013
	Revision No.	3
	Date of Rev.	01.06.2019

Report No. -03

Date of sample collection: - 14.06.2022

Date of Analysis: 14.06.2022 to 17.06.2022

Sr.No.	Parameter	Unit	Nala Up Stream	Nala Down Stream	Standards norms as per IS 2296
1	pH	-	7.30	7.45	6.5 - 8.5
2	Colour	Hazen	Colourless	Colourless	300
3	Odour	-	Unobjectionable	Unobjectionable	Unobjectionable
4	Chloride	mg/L	141.0	143.1	-
5	Total Hardness as CaCO ₃	mg/L	15.2	13.1	300
6	Suspended Solids	mg/L	84.1	81.5	-
7	Total Dissolve Solids	mg/L	84	83.1	500
8	Chemical Oxygen Demand	mg/L	ND	ND	-
9	Biochemical Oxygen Demand (For 3 days at 27 °C)	mg/L	ND	ND	2.0
10	Oil & Grease	mg/L	ND	ND	-
11	Temperature	° C	24.0	24.0	-
12	Conductivity	μS/cm	337.50	326.5	-



Analysis By



Checked BY



Verified By